


**Photographs of Log Books and
Other Records Regarding
Maintenance Works**

Generator Maintenance Register



[Handwritten Signature]
Principal

Army College Of Dental Sciences

Generator Maintenance Register – Inner Pages

Sr. No.	Date	Generator On Time	Generator Off Time	Generator Duration	Water Pressure	Total Diesel	Consumption	Balance Diesel	APF	APF Status	APF Signature
1	23/08/20	04:00 AM	04:55 PM	45 mins	1112.2	365	44.5	15.24	35.88	Rings	
2	23/08/20	10:28 AM	11:36 AM	01:10 min	1112.8	350	14.5	84.19	32.68	Rings	
3	23/08/20	02:20 PM	02:50 PM	08 mins	1112.4	326	11.5	03.11	30.3	Rings	
4	23/08/20	03:58 PM	04:24 PM	06 mins	112.5	323	11	03.11	32.0	Rings	
5	24/08/20	11:00 AM	11:17 AM	16 mins	1112.2	380	15	04.11	31.6	Rings	
6	24/08/20	01:28 PM	01:32 PM	8 mins	1112.2	316	11	03.11	31.2	Rings	
7	24/08/20	02:33 PM	02:53 PM	20 mins	1113.2	313	11	02.17	30.8	Rings	
8	24/08/20	03:00 PM	03:18 PM	16 mins	1114.0	306	10	16.5	29.01	Rings	
9	24/08/20	10:45 AM	10:52 AM	07 mins	1114.1	290	11	03.11	28.7	Rings	
10	24/08/20	05:50 PM	05:52 PM	30 mins	1114.6	287	11	11.11	28.1	Rings	
11	24/08/20	06:55 PM	07:00 PM	06 mins	1114.7	294	11	03.11	27.8	Rings	
12	24/08/20	08:40 AM	08:55 AM	18 mins	1115.0	273	11	07.11	26.6	Rings	
13	24/08/20	08:40 AM	08:45 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
14	24/08/20	08:45 AM	08:50 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
15	24/08/20	08:50 AM	08:55 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
16	24/08/20	08:55 AM	09:00 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
17	24/08/20	09:00 AM	09:05 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
18	24/08/20	09:05 AM	09:10 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
19	24/08/20	09:10 AM	09:15 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
20	24/08/20	09:15 AM	09:20 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
21	24/08/20	09:20 AM	09:25 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
22	24/08/20	09:25 AM	09:30 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
23	24/08/20	09:30 AM	09:35 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
24	24/08/20	09:35 AM	09:40 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
25	24/08/20	09:40 AM	09:45 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
26	24/08/20	09:45 AM	09:50 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
27	24/08/20	09:50 AM	09:55 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
28	24/08/20	09:55 AM	10:00 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
29	24/08/20	10:00 AM	10:05 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
30	24/08/20	10:05 AM	10:10 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
31	24/08/20	10:10 AM	10:15 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
32	24/08/20	10:15 AM	10:20 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
33	24/08/20	10:20 AM	10:25 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
34	24/08/20	10:25 AM	10:30 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
35	24/08/20	10:30 AM	10:35 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
36	24/08/20	10:35 AM	10:40 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
37	24/08/20	10:40 AM	10:45 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
38	24/08/20	10:45 AM	10:50 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
39	24/08/20	10:50 AM	10:55 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
40	24/08/20	10:55 AM	11:00 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
41	24/08/20	11:00 AM	11:05 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
42	24/08/20	11:05 AM	11:10 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
43	24/08/20	11:10 AM	11:15 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
44	24/08/20	11:15 AM	11:20 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
45	24/08/20	11:20 AM	11:25 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
46	24/08/20	11:25 AM	11:30 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
47	24/08/20	11:30 AM	11:35 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
48	24/08/20	11:35 AM	11:40 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
49	24/08/20	11:40 AM	11:45 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
50	24/08/20	11:45 AM	11:50 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
51	24/08/20	11:50 AM	11:55 AM	05 mins	1115.1	273	11	03.11	26.6	Rings	
52	24/08/20	11:55 AM	12:00 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
53	24/08/20	12:00 PM	12:05 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
54	24/08/20	12:05 PM	12:10 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
55	24/08/20	12:10 PM	12:15 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
56	24/08/20	12:15 PM	12:20 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
57	24/08/20	12:20 PM	12:25 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
58	24/08/20	12:25 PM	12:30 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
59	24/08/20	12:30 PM	12:35 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
60	24/08/20	12:35 PM	12:40 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
61	24/08/20	12:40 PM	12:45 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
62	24/08/20	12:45 PM	12:50 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
63	24/08/20	12:50 PM	12:55 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
64	24/08/20	12:55 PM	01:00 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
65	24/08/20	01:00 PM	01:05 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
66	24/08/20	01:05 PM	01:10 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
67	24/08/20	01:10 PM	01:15 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
68	24/08/20	01:15 PM	01:20 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
69	24/08/20	01:20 PM	01:25 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
70	24/08/20	01:25 PM	01:30 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
71	24/08/20	01:30 PM	01:35 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
72	24/08/20	01:35 PM	01:40 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
73	24/08/20	01:40 PM	01:45 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
74	24/08/20	01:45 PM	01:50 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
75	24/08/20	01:50 PM	01:55 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
76	24/08/20	01:55 PM	02:00 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
77	24/08/20	02:00 PM	02:05 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
78	24/08/20	02:05 PM	02:10 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
79	24/08/20	02:10 PM	02:15 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
80	24/08/20	02:15 PM	02:20 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
81	24/08/20	02:20 PM	02:25 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
82	24/08/20	02:25 PM	02:30 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
83	24/08/20	02:30 PM	02:35 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
84	24/08/20	02:35 PM	02:40 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
85	24/08/20	02:40 PM	02:45 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
86	24/08/20	02:45 PM	02:50 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
87	24/08/20	02:50 PM	02:55 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
88	24/08/20	02:55 PM	03:00 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
89	24/08/20	03:00 PM	03:05 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
90	24/08/20	03:05 PM	03:10 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
91	24/08/20	03:10 PM	03:15 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
92	24/08/20	03:15 PM	03:20 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
93	24/08/20	03:20 PM	03:25 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
94	24/08/20	03:25 PM	03:30 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
95	24/08/20	03:30 PM	03:35 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
96	24/08/20	03:35 PM	03:40 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
97	24/08/20	03:40 PM	03:45 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
98	24/08/20	03:45 PM	03:50 PM	05 mins	1115.1	273	11	03.11	26.6	Rings	
99											

Generator Maintenance Register – Inner Pages

Sr	Date	Generator On time	Off time	To To Rating	meter Reading	to fuel used	Consumed diesel	Balance diesel	ABO Strs	ADM Strs
1	29/5/2021	5:45	6:10	25 mins	00032.5	173	8 Litres	165	N Power	
2	31/5/2021	8:45	11:50	09:55 mins	00040.3	165	62 Litres	103	N Power	
		Received		Deceased		200 Litres				
3	31/5/2021	3:10	3:20	10 mins	00040.4	303	2	301	N Power	
4	1/6/2021	7:36	7:46	10 mins	00040.6	301	2	299	N Power	
5	10/6/2021	4:10	4:20	10 mins	00040.7	299	2	997	N Power	
6	14/06/2021	11:00	12:02	1 Bomb	00042.9	297	20 Litres	277	ma Koffler	
7	17/06/2021	12:00	12:22	22 mins	00043.3	277	6 Litres	271	ma Koffler	
8	17/06/2021	2:14	2:34	20 mins	00044.1	271	2	269	N Power	
9	21/06/2021	3:35	4:16	41 mins	00044.9	269	6	263	N Power	
10	04/07/2021	7:50	4:00	10 mins	00045.8	263	3 litres	260	ma Koffler	
11	05/07/2021	7:00	7:31	30 mins	00046.7	260	10	250	ma Koffler	
12	06/07/2021	8:30	7:15	45 mins	00048.1	250	11 litres	239	ma Koffler	
13	07/07/2021	10:30	10:54	24 mins	00048.3	239	5	234	N Power	
14	10/07/2021	10:59	11:25	26 mins	00048.5	239	7	227	N Power	
15	21/07/2021	11:13	12:15	1:02 mins	00048.9	227	20	207	N Power	
16	22/07/2021	2:12 AM	4:09 AM	1:57	00049.2	207	40	167	N Power	
17	22/07/2021	5:31 AM	7:51 PM	2:27	00049.6	167	48	119	N Power	
18	22/07/2021	7:33 PM	8:42 PM	1:09 mins	00049.9	119	23	96	N Power	
		Received		Deceased		200 Litres				
19	24/07/2021	8:30	8:40	10 mins	00050.1	296	10	294	N Power	
20	30/07/2021	10:30	9:45	4:45 mins	00051.9	294	88 mins	206	N Power	
		Received		Deceased		200 Litres				
21	31/08/2021	11:14	11:35	21 mins	00051.9	406	07 mtr	399		
22	05/08/2021	6:50	6:26	26 mins	00051.9	399	11	388		
23	09/08/2021	7:02	07:25	23 mins	00060.2	388	06	382		
24	01/08/2021	12:00	12:31	28 mins	00061.8	382	28/10	372		
25	16/08/2021	04:50	04:52	29 mins	00062.3		10	362		
26	02/08/2021	04:04:31	10:05	34 mins	00063.5		11	351		
27	17/08/2021	2:47	2:35	09 mins	00062.6	351	02	349		
28	06/09/2021	11:02	11:42	40 mins	00062.9	349	12	337		

305

FOL COUPON : ACDS DRIVER COPY

Vehicle No: Gen 305
 Date of Last Filing: 22/07/21
 Kms at last Filing: _____
 No of Ltrs Filled Last: _____
 Kms Reading now: _____
 Kms Run: _____
 KPL: SHIKHAR FILLING STATION
 No of Ltrs Filled now: _____
 Cost - Rs: _____
 Signature of Driver: _____
 Signature of Co Driver: _____
 Signature of Pump Owner: _____

307

FOL COUPON : ACDS DRIVER COPY

Vehicle No: Gen 307
 Date of Last Filing: 30/7/21
 Kms at last Filing: _____
 No of Ltrs Filled Last: _____
 Kms Reading now: 202/14
 Kms Run: _____
 KPL: _____ / Ltrs
 No of Ltrs Filled now: _____
 Cost - Rs: _____
 Signature of Driver: _____
 Signature of Co Driver: _____
 Signature of Pump Owner: _____

Principal
Army College Of Dental Sciences



Dental Chair Maintenance Register



ARMY COLLEGE OF DENTAL SCIENCES

File No: ACDS/CONS & ENDO/DS/F2/C/R

Name of the Department :- Department of Conservative
Dentistry and Endodontics

Subject :- Dental Chair Maintenance

Opened on: 1/06/2013

Closed on:

To be retained till 10 years

In-charge Reader 3

ARMY COLLEGE OF DENTAL SCIENCES
DEPARTMENT OF _____

VERIFIED BY: PROFESSOR & HEAD

DAILY WEEKLY FORTNIGHTLY

MONTHLY QUARTERLY HALF-YEARLY YEARLY

SIGNATURE:



Principal
Army College Of Dental Sciences

Dental Chair Maintenance Register – Inner Pages

DENTAL CHAIR NUMBER	MOVEMENT	LIGHT	SPITTOON/TUMBLER	THREE-WAY SPRINGER	AIRGATE	MILKOMETER	INSTRUMENT HOLDER	OPERATOR	ANY BROKEN ITEM	HEAD REST/AGAIN	MISC.	DATE OF REPORTING	SIGNATURE	DATE OF REPAIR	SIGNATURE
3	✓	✓	✓	✓	✓	✓	✓	✓	-	✓	-				
	✓	✓	✓	✓	✓	✓	✓	✓	-	✓	-				
CON-34	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	30/11/14	Signature		
												2/12/14	Signature	11/12/14	
												03/12/14	Signature	03/12/14	
												15/12/14	Signature	15/12/14	
												17/12/14	Signature	17/12/14	
												28/12/14	Signature	28/12/14	
												02/01/15	Signature	02/01/15	
												12/01/15	Signature	12/01/15	
												17/01/15	Signature	17/01/15	
												18/02/15	Signature	18/02/15	
												20/02/15	Signature	20/02/15	
												12/12/15	Signature	12/12/15	
												14/02/16	Signature	14/02/16	
												26/02/16	Signature	26/02/16	
												12/03/16	Signature	12/03/16	
												11/03/16	Signature	11/03/16	
												14/03/16	Signature	14/03/16	
												12/04/16	Signature	12/04/16	
												14/04/16	Signature	14/04/16	
												19/05/16	Signature	19/05/16	

DENTAL CHAIR NUMBER	MOVEMENT	LIGHT	SPITTOON/TUMBLER	THREE-WAY SPRINGER	AIRGATE	MILKOMETER	INSTRUMENT HOLDER	OPERATOR	ANY BROKEN ITEM	HEAD REST/AGAIN	MISC.	DATE OF REPORTING	SIGNATURE	DATE OF REPAIR	SIGNATURE
2	✓	✓	✓	✓	✓	✓	✓	✓	-	✓	-				
	✓	✓	✓	✓	✓	✓	✓	✓	-	✓	-				
CON-33	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	30/11/14	Signature	11/12/14	
												2/12/14	Signature	11/12/14	
												02/12/14	Signature	02/12/14	
												05/12/14	Signature	05/12/14	
												11/12/14	Signature	11/12/14	
												13/12/14	Signature	13/12/14	
												22/12/14	Signature	22/12/14	
												15/01/15	Signature	15/01/15	
												25/01/15	Signature	25/01/15	
												04/02/15	Signature	04/02/15	
												11/02/15	Signature	11/02/15	
												30/02/15	Signature	30/02/15	
												12/10/15	Signature	12/10/15	
												23/11/15	Signature	23/11/15	
												27/11/15	Signature	27/11/15	
												28/11/15	Signature	28/11/15	
												24/02/16	Signature	24/02/16	
												23/02/16	Signature	23/02/16	
												28/02/16	Signature	28/02/16	
												08/02/16	Signature	08/02/16	
												14/02/16	Signature	14/02/16	



 Principal

Dental Chair Maintenance Register – Inner Pages

DENTAL CHAIR NUMBER	MOVEMENT	LIGHT	SPITTOON TUMBLER & TRAYS	AIRTOR	MICROTOR	SUCTION	REPAIRS	HEAD ASST. REPAIRS	MISC.	DATE OF REPORTING	SIGN.	DATE OF REPAIR	SIGN. OF STAFF
14	✓	✓	✓	✓	✓	✓							
CON 48													
										30/1/13			
										4/4/14			
										09/09/14			
										09/09/14			
										14/10/14			
										14/11/14			
										18/1/15			
										21/1/15			
										23/1/15			
										12/2/15			
										22/2/15			
										14/2/16			
										21/2/16			
										21/2/16			
										22/2/16			
										27/2/16			
										22/2/16			
										15/11/16			
										22/12/16			
										11/10/17			
										22/10/17			
										14/12/17			
										24/12/17			
										24/12/17			
										20/05/17			
										17/06/17			

DATE	TIME	DESCRIPTION	REPAIRS	HEAD ASST. REPAIRS	MISC.	DATE OF REPORTING	SIGN.	DATE OF REPAIR	SIGN. OF STAFF
14-04-18	P4	Chair no: 58: Suction problem solved & working							
"	P4	Chair no: 57: Air pressure leakage problem solved.							
"	U4	Chair no: 55: Light changed & working.							
"	U4	Chair no: 55: Light changed & working.							
14-04-18	U4	Chair no: 54: Air pressure problem solved & OK.							
14-04-18	U4	Air Valve changed. micro escape. OK.							
14-04-18	U4	Chair no: 32: Airtor and water control problem solved & working.							
14-04-18	U4	Chair no: 45: Airtor water leakage problem solved & working.							
14-04-18	P4	Chair no: 10: Suction problem solved & OK.							
14-04-18	P4	Chair no: 32: Air pressure problem solved & OK.							
14-04-18	P4	Chair no: 10: Air pressure leakage problem solved & OK.							
14-04-18	U4	Chair no: 32: Air pressure leakage problem solved.							
14-04-18	P4	Chair no: 58: Suction motor problem solved.							
14-04-18	P4	Chair no: 10: Air pressure leakage problem solved & OK.							
14-04-18	U4	Chair no: 32: Air pressure leakage problem solved.							

**Sec' bad
800 087**

Principal

Army College Of Dental Sciences

Principal